3-Phase AC Filters / DC Filters https://www.schurter.com /PG80

FMAD NEO

1-stage filter for 3-phase systems





- Terminals for three phases, neutral conductor and ground

- Industrial or low leakage current versions

Case 5B-16

Description

- 1 stage





See below: **Approvals and Compliances**

Applications

- Voltage rating 520 VAC for world wide acceptance
- Protection against interference voltage from the mains
- Especially designed for industrial applications such as: Frequency Converters, Stepper Motor Drives, UPS-Systems, Inverters
- Suitable for use in equipment according to IEC/UL 62368-1

Weblinks

pdf data sheet, html datasheet, General Product Information, Approvals, Distributor-Stock-Check, Detailed request for product, Microsite

- Wide temperature range

- Light weight design

- Very high attenuation

Unique Selling Proposition - Compact design with small footprint

- Single-stage filter for high efficiency

Technical Data

Rated Current	16 - 230A
Rated voltage	300/520 VAC, 50/60 Hz
Approval for	16 - 230 A @ 50 °C / 300/520 VAC; 50/60 Hz
Overload Current	1.5 x lr for 1 minute, per hour
Dielectric Strength	> 2.25 kVDC between L-L > 2.75 kVDC between L-PE Test voltage 2 sec
Number of Filter Stages	1-stage
Weight	0.9 - 4.1 kg
Material: Housing	Metal
Sealing Compound	UL 94V-0

Mounting	Screw-on mounting on chassis
Terminal	Screw clamps
Operating Temperature	-40 °C to 100 °C
Climatic Category	40/100/21 acc. to IEC 60068-1
Degree of Protection	IP20 acc. to IEC 60529
Protection Class	Suitable for appliances with protection class I acc. to IEC 61140
MTBF	> 200'000h acc. to MIL-HB-217 F

Approvals and Compliances

Detailed information on product approvals, code requirements, usage instructions and detailed test conditions can be looked up in Details about Approvals

SCHURTER products are designed for use in industrial environments. They have approvals from independent testing bodies according to national and international standards. Products with specific characteristics and requirements such as required in the automotive sector according to IATF 16949, medical technology according to ISO 13485 or in the aerospace industry can be offered exclusively with customer-specific, individual agreements by SCHURTER.

Approvals

The approval mark is used by the testing authorities to certify compliance with the safety requirements placed on electronic products.

Approval Reference Type: FMAD NEO

Approval Logo	Certificates	Certification Body	Description
10	VDE Approvals	VDE	Certificate Number: 40049000
c FN us	UL Approvals	UL	UL File Number: E495089

Product standards

Product standards that are referenced

Organization	Design	Standard	Description
IEC	Designed according to	IEC 60939	Passive filters for suppressing electromagnetic interference
(^j L)	Designed according to	UL 1283	Electromagnetic interference filters

FMAD NEO

Application standards

Application standards where the product can be used

RoHS

REACH

China RoHS

101000000000000000000000000000000000000			
Organization	Design	Standard	Description
IEC.	Designed for applications acc. IEC/U		IEC 62368-1 includes the basic requirements for safety of audio, video, information technology and office equipment.
Compliances The product comp	lies with following Guide Lines		
Identification	Details	Initiator	Description
CE	CE declaration of conformity	SCHURTER AG	The CE marking declares that the product complies with the applicable requirements laid down in the harmonisation of Community legislation on its affixing in accordance with EU Regulation 765/2008.

SCHURTER AG

SCHURTER AG

SCHURTER AG

0

RoHS

REACH

The law SJ / T 11363-2006 (China RoHS) has been in force since 1 March

Directive RoHS 2011/65/EU, Amendment (EU) 2015/863

2007. It is similar to the EU directive RoHS. On 1 June 2007, Regulation (EC) No 1907/2006 on the Registration, Evaluation, Authorization and Restriction of Chemicals 1 (abbreviated as "REACH") entered into force.

Dimension [mm]

Case 5A-4

Case 5A-10



Case 5B-10

Case 5B-16



Case 5C-25

Case 5C-50



Case 5D-95



Diagrams



FMAD NEO

100 MHz

Attenuation Loss

- - - - 50 Ω differential mode _____ 50 Ω common mode



230 A



Low leakage current version



64 A



All Variants

Rated Current @ Ta 50°C [A]	Filter Type	Tripped Power Dissipation [W]	Contact Resistance [m Ω]	Leakage Cur- rent [mA] @ 440V, 60Hz 1)	Weight [kg]	Screw clamps [mm2] 2)	Housings	Order Number
16	Industrial version	1.5	5.7	10.5	0.9 kg	4	5A-4	3-108-700
25	Industrial version	1.6	2.5	10.7	1.1 kg	10	5A-10	3-108-701
36	Industrial version	2.1	1.65	10.7	1.3 kg	10	5B-10	3-108-712
50	Industrial version	4.1	1.65	11.4	1.3 kg	10	5B-10	3-108-713
64	Industrial version	3.9	0.94	11.4	1.35 kg	16	5B-16	3-108-714
80	Industrial version	5.2	0.82	12.2	1.45 kg	25	5C-25	3-108-715
110	Industrial version	6.3	0.52	12.2	2.5 kg	50	5C-50	3-108-716

Rated Current @ Ta 50°C [A]	Filter Type	Tripped Power Dissipation [W]	Contact Resistance [m Ω]	Leakage Cur- rent [mA] @ 440V, 60Hz 1)	Weight [kg]	Screw clamps [mm2] 2)	Housings	Order Number	
180	Industrial version	12	0.37	12.2	3.1 kg	95	5D-95	3-108-717	
230	Industrial version	14.3	0.27	13.1	4.1 kg	95	5D-95	3-108-718	
16	Low leakage current version	1.5	5.7	1.4	0.9 kg	4	5A-4	3-109-852	
25	Low leakage current version	1.6	2.5	3	1.1 kg	10	5A-10	3-109-853	
36	Low leakage current version	2.1	1.65	3	1.3 kg	10	5B-10	3-109-854	
50	Low leakage current version	4.1	1.65	3	1.3 kg	10	5B-10	3-109-855	
64	Low leakage current version	3.9	0.94	3	1.35 kg	16	5B-16	3-109-856	

Most Popular.

Availability for all products can be searched real-time:https://www.schurter.com/en/Stock-Check/Stock-Check-SCHURTER

1) Leakage current according IEC 60939-1

2) Maximum conductor cross section (wire gauge) to be used; a comparative table for AWG and mm² values can be found in the general product information https://www.schurter.com/en/FAQ#10

Packaging unit 1 Pcs

The specifications, descriptions and illustrations indicated in this document are based on current information. All content is subject to modifications and amendments. Information furnished is believed to be accurate and reliable. However, users should independently evaluate the suitability and test each product selected for their own applications.