

Double-level terminal block - PTTBS 2,5-TWIN/2P - 3210604

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Double-level terminal block, Cross section: 0.14 mm² - 4 mm², AWG: 26 - 12, Connection type: Push-in connection, Width: 5.2 mm, Color: gray, Mounting type: NS 35/7,5, NS 35/15

Product Features

- The Push-in connection terminal blocks are characterized by the system features of the CLIPLINE complete system and by easy and tool-free wiring of conductors with ferrules or solid conductors
- ☑ In addition to the testing facility in the double function shaft, all terminal blocks provide an additional test connection



Key Commercial Data

Packing unit	1 pc
Minimum order quantity	50 pc
Custom tariff number	85369010
Country of origin	Poland

Technical data

General

Number of levels	2
Number of connections	5
Nominal cross section	2.5 mm ²
Color	gray
Insulating material	PA
Flammability rating according to UL 94	V0
Rated surge voltage	6 kV
Overvoltage category	III
Insulating material group	I
Connection in acc. with standard	IEC 60947-7-1
Nominal current I _N	22 A



Double-level terminal block - PTTBS 2,5-TWIN/2P - 3210604

Technical data

General

Nominal voltage U _N Open side panel Insertion/withdrawal cycles mechanical Surge voltage test setpoint Result of surge voltage test Power frequency withstand voltage setpoint Result of power-frequency withstand voltage test Setpoint Result of tight fit test Conductor cross section short circuit testing Short-time current Short circuit stability result Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test passed DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency F ₁ = 5 Hz to f ₂ = 150 Hz	
Insertion/withdrawal cycles mechanical Surge voltage test setpoint Result of surge voltage test Power frequency withstand voltage setpoint Result of power-frequency withstand voltage test Test passed Setpoint 1 N Result of tight fit test Conductor cross section short circuit testing Short-time current O.3 kA Short circuit stability result Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test passed Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency f ₁ = 5 Hz to f ₂ = 150 Hz	
Surge voltage test setpoint Result of surge voltage test Test passed Power frequency withstand voltage setpoint 1.89 kV Result of power-frequency withstand voltage test Test passed Setpoint 1 N Result of tight fit test Conductor cross section short circuit testing 2.5 mm² Short-time current 0.3 kA Short circuit stability result Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency f ₁ = 5 Hz to f ₂ = 150 Hz	
Result of surge voltage test Power frequency withstand voltage setpoint 1.89 kV Result of power-frequency withstand voltage test Setpoint 1 N Result of tight fit test Conductor cross section short circuit testing Short-time current 0.3 kA Short circuit stability result Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test passed Test passed Test passed Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency f ₁ = 5 Hz to f ₂ = 150 Hz	
Power frequency withstand voltage setpoint 1.89 kV Result of power-frequency withstand voltage test Setpoint 1 N Result of tight fit test Conductor cross section short circuit testing 2.5 mm² Short-time current 0.3 kA Short circuit stability result Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency f ₁ = 5 Hz to f ₂ = 150 Hz	
Result of power-frequency withstand voltage test Setpoint 1 N Result of tight fit test Conductor cross section short circuit testing 2.5 mm² Short-time current 0.3 kA Short circuit stability result Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test passed	
Setpoint1 NResult of tight fit testTest passedConductor cross section short circuit testing 2.5 mm^2 Short-time current 0.3 kA Short circuit stability resultTest passedProof of thermal characteristics (needle flame) effective duration 30 s Result of thermal testTest passedTest specification, oscillation, broadband noiseDIN EN 50155 (VDE 0115-200):2008-03Test spectrumService life test category 1, class B, body mountedTest frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Result of tight fit testTest passedConductor cross section short circuit testing 2.5 mm^2 Short-time current 0.3 kA Short circuit stability resultTest passedProof of thermal characteristics (needle flame) effective duration 30 s Result of thermal testTest passedTest specification, oscillation, broadband noiseDIN EN 50155 (VDE 0115-200):2008-03Test spectrumService life test category 1, class B, body mountedTest frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Conductor cross section short circuit testing 2.5 mm^2 Short-time current 0.3 kA Short circuit stability resultTest passedProof of thermal characteristics (needle flame) effective duration 30 s Result of thermal testTest passedTest specification, oscillation, broadband noiseDIN EN 50155 (VDE 0115-200):2008-03Test spectrumService life test category 1, class B, body mountedTest frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Short-time current 0.3 kA Short circuit stability result Test passed Proof of thermal characteristics (needle flame) effective duration 30 s Result of thermal test Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Short circuit stability result Proof of thermal characteristics (needle flame) effective duration Result of thermal test Test passed Test passed Test passed DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Proof of thermal characteristics (needle flame) effective duration 30 s Result of thermal test Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Result of thermal testTest passedTest specification, oscillation, broadband noiseDIN EN 50155 (VDE 0115-200):2008-03Test spectrumService life test category 1, class B, body mountedTest frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Test spectrumService life test category 1, class B, body mountedTest frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
Test frequency $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$	
ASD level $0.964 \text{ (m/s}^2)^2/\text{Hz}$	
Acceleration 0.58 g	
Test duration per axis 5 h	
Test directions X-, Y- and Z-axis	
Oscillation, broadband noise test result Test passed	
Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03	
Shock form Half-sine	
Acceleration 5 g	
Shock duration 30 ms	
Number of shocks per direction 3	
Test directions X-, Y- and Z-axis (pos. and neg.)	
Shock test result Test passed	
Temperature index, insulating material (DIN EN 60216-1 (VDE 0304-21)) 125 °C	
Static insulating material application in cold -60 °C	

Dimensions

Width	5.2 mm
Length	111.8 mm
Height NS 35/7,5	55 mm



Double-level terminal block - PTTBS 2,5-TWIN/2P - 3210604

Technical data

Dimensions

Height NS 35/15	62.5 mm
Ticigni 140 do, 10	02.5 11111

Connection data

Connection method	Push-in connection
Conductor cross section solid min.	0.14 mm²
Conductor cross section solid max.	4 mm²
Conductor cross section flexible min.	0.14 mm ²
Conductor cross section flexible max.	2.5 mm²
Conductor cross section AWG min.	26
Conductor cross section AWG max.	12
Conductor cross section flexible, with ferrule without plastic sleeve min.	0.14 mm²
Conductor cross section flexible, with ferrule without plastic sleeve max.	2.5 mm²
Conductor cross section flexible, with ferrule with plastic sleeve min.	0.14 mm²
Conductor cross section flexible, with ferrule with plastic sleeve max.	2.5 mm²
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max.	0.5 mm²
Minimum stripping length	8 mm
Maximum stripping length	10 mm
Internal cylindrical gage	A3

Classifications

eCl@ss

eCl@ss 5.1	27141120
eCl@ss 6.0	27141120

ETIM

ETIM 5.0	EC000897

Drawings

Circuit diagram

∞→

Phoenix Contact 2015 © - all rights reserved http://www.phoenixcontact.com