Würth Elektronik eiSos GmbH & Co. KG **EMC & Inductive Solutions**

Max-Eyth-Straße 1 · 74638 Waldenburg · Germany Tel. +49 (0) 79 42 945-0 · Fax +49 (0) 79 42 945-400 eiSos@we-online.de · www.we-online.de



Product / F □ Major change ⊠ Minor change	Process Change Notification	on (PCN)
PCN #:	PCN_WCAP-PHGP_20191002	Change Category:
Affected Series:	WCAP-PHGP; 875015119004 / 875015119005	□ Equipment / Location☑ General Data□ Material□ Process
PCN Date:	September 02, 2019	☐ Product Design
Effective Date:	October 02, 2019	☐ Shipping / Packaging☐ Supplier☐ Software
Contact:	Product Management	Data Sheet Change:
Phone:	+49 (0) 7942 - 945 5001	⊠ Yes □ No
Fax:	+49 (0) 7942 - 945 5179	Attachment:
E-Mail:	pcn.eisos@we-online.com	☐ Yes
Because of a databa	PURPOSE OF CHANGE: ase mismatch, Würth Elektronik will update the Rip age in form, fit, function, quality or reliability of the	•
DETAIL OF CHANG	E:	
For part 8750151190	004:	

Old datasheet:

New datasheet:

Electrical Properties:

Properties		Test conditions	Value	Unit	Tol.
Capacitance	С	0.5 W 120 Hz/ +20 °C	150	μF	±20%
Rated Voltage	U _R		6.3	V (DC)	max.
Surge Voltage	U _S	1000 cycles @ 20 °C	7.8	V (DC)	max.
Leakage Current	Leak	2 min./ +20 °C	94.5	μΑ	max.
Dissipation Factor	DF	0.5 W 120 Hz/ +20 °C	6	96	max.
Ripple Current	IRIPPLE	100 kHz @ 45 °C	5100	mA	max.
ESR	R _{ESR}	100 kHz @ 20°C	15	mΩ	max.

Electrical Propertie	es:
Properties	

Properties		Test conditions	Value	Unit	Tol.
Capacitance	С	0.5 V/ 120 Hz/ +20 °C	150	μF	±20%
Rated Voltage	U _R		6.3	V (DC)	max.
Surge Voltage	U _S	1000 cycles @ 20 °C	7.8	V (DC)	max.
Leakage Current	Leak	2 min./ +20 °C	94.5	μА	max.
Dissipation Factor	DF	0.5 V/ 120 Hz/ +20 °C	6	%	max.
Ripple Current	IRPPLE	100 kHz @ 45 °C	5600	mA	max.
ESR	Resp	100 kHz @ 20°C	12	mΩ	max.

The ripple current (IRIPPLE) has been corrected from "5100 mA" to "5600 mA".

The equivalent series resistance (R_{ESR}) has been corrected from "15 m Ω " to "12 m Ω ".

Würth Elektronik eiSos GmbH & Co. KG EMC & Inductive Solutions

$$\label{eq:max-ey} \begin{split} \text{Max-Eyth-Straße 1} & \cdot \text{74638 Waldenburg} \cdot \text{Germany} \\ \text{Tel.} & +49 \text{ (0)} \text{ 79} \text{ 42} \text{ 945-0} \cdot \text{Fax} \text{ +49 (0)} \text{ 79} \text{ 42} \text{ 945-400} \\ \text{eiSos@we-online.de} & \cdot \text{www.we-online.de} \end{split}$$



For part 875015119005:

Old datasheet:

Electrical Properties:

Liectifical Flope	ucs.				
Properties		Test conditions	Value	Unit	Tol.
Capacitance	С	0.5 V/ 120 Hz/ +20 °C	180	μF	±20%
Rated Voltage	U _R		6.3	V (DC)	max.
Surge Voltage	U _S	1000 cycles @ 20 °C	7.8	V (DC)	max.
Leakage Current	Leak	2 min./ +20 °C	113.4	μА	max.
Dissipation Factor	DF	0.5 V/ 120 Hz/ +20 °C	6	%	max.
Ripple Current	I _{RIPPLE}	100 kHz @ 45 °C	5100	mA	max.
ESR	Bren	100 kHz @ 20°C	12	mΩ	max.

New datasheet:

Electrical Properties:

Properties		Test conditions	Value	Unit	Tol.
Capacitance	С	0.5 V/ 120 Hz/ +20 °C	180	μF	±20%
Rated Voltage	U _B		6.3	V (DC)	max.
Surge Voltage	U _S	1000 cycles @ 20 °C	7.8	V (DC)	max.
Leakage Current	ILeak	2 min./ +20 °C	113.4	μΑ	max.
Dissipation Factor	DF	0.5 V/ 120 Hz/ +20 °C	6	%	max.
Ripple Current	IRIPPLE	100 kHz @ 45 °C	5100	mA	max.
ESR	R _{ESR}	100 kHz @ 20°C	15	mΩ	max.

The equivalent series resistance (R_{ESR}) has been corrected from "12 m Ω " to "15 m Ω ".

RELIABILITY / QUALIFICATION SUMMARY:

There will be no change of the product, therefore no additional reliability or qualification testing will be performed.