SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 UL LISTED: UL 935

CSA CERTIFIED: CSA C22.2 No. 8 VDE APPROVED: EN 60939-2

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 5.0 AMP/50°C, 277 VAC 50-60Hz (UL&CSA) 5.0 AMP/50°C, 277 VDC (UL&CSA) 5.0 AMP/50°C, 250 VAC 50-60Hz (VDE)

5.0 AMP/50°C, 250 VDC (VDE)

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND:

0.28 mA @ 277V 60Hz 0.21 mA @ 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +50°C @ RATED CURRENT, Ir.

IN AN AMBIENT, T_0 , HIGHER THAN 50°C, THE MAXIMUM OPERATING CURRENT, I_0 , IS AS FOLLOWS: $T_0 = T_0$ $T_0 = T_0$

<u>85 - Ta</u> 35 $I_0 = I_r -$

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES In FOR 8 SECONDS

CUSTOMER DRAWING		
CATALOG :	# 5FB3	
ECN#	APPRVD	
/	PJ0	28FEB12

TEST SPECIFICATIONS:

INDUCTANCE: 0.42 mH NOMINAL (WHITE) 0.44 mH NOMINAL (BLACK)

CAPACITANCE: (MEASURED e 1 kHz, 0.250VAC MAX., 25°C±1°C)
LINE TO GROUND: 0.0044uF ± 20 %
LINE TO LINE: 0.33uF ± 20 %
DISCHARGE RESISTOR: 1 MEGOHM

L/G AND L/L 1.R.

NO DISCHARGE RESISTOR: 6000MEGOHM (MIN.) 100VDC 20°C AND 50% RH

RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 2300 VDC FOR 1 MINUTE LINE TO LINE: 1853 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.

