

**Application Spotlight** 

# Thermistors FAQ



#### **Thermistors FAQ**

What are the Individual Parameters of a Thermistor?

Parameters include Zero-load Resistance Value, Beta ( $\beta$ ) Constant, Ratio, Alpha ( $\alpha$ ), Thermal Time Constant ( $\tau$ ), Dissipation Constant ( $\delta$ ).

What is the Zero-load Resistance Value?

Zero-load Resistance Value is the resistance value of a thermistor measured at a prescribed temperature, also called no-load resistance value. The value is normally measured at a standard temperature of 25°C (R25). The measurement is conducted at a power level such that the influences of spontaneous heat generation can be negligible.

## What is Beta ( $\beta$ ) Constant?

The Beta Constant, shown in Figure 3, is the slope of the NTC thermistors resistance to temperature characteristic (in kelvins) over a specified temperature range according to the formula:





What is the Ratio?

The Ratio is the ratio of the resistance of a thermistor at two different temperature points.

What is the Alpha ( $\alpha$ )?

What is the Thermal

Time Constant  $(\tau)$ ?

The Alpha is the zero-power temperature coefficient of resistance, which is the ratio at a specified temperature, of the rate of change of zero-power resistance with temperature to the zero-power resistance of the thermistor. Put simply, it is the % change in resistance per degree C change in temperature at a specified temperature.

Thermal Time Constant, as shown in Figure 4, is the time required for a thermistor to change 63.2% of the total difference between its initial and final body temperature when subjected to a step function change in temperature under zero-power conditions.



 $\beta = \left[\frac{T \times T_0}{T_0 - T}\right] \times \ln\left[\frac{R_T}{R_{T_0}}\right]$ 

### What is the Dissipation Constant $(\bar{0})$ ?

Dissipation Constant is the ratio, (in milliwatts per degree C) at a specified ambient temperature, of a change in power dissipation in a thermistor to the resultant body temperature change. Simply, it is the power required to change the thermistor by 1°C through self-heating.



#### www.amphenol-sensors.com

© 2018 Amphenol Corporation. All Rights Reserved. Specifications are subject to change without notice.