### SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROYED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA C22.2 No. 8 VDE APPROVED: EN 60939-2

### OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE:

AMP/40°C 120/250 VAC, 50-60Hz AMP/40°C, 250 VAC, 50-60Hz AMP/40°C, 250 VDC

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND:

0.75mA @ 120V 60Hz

1.25mA @ 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, Ir. IN AN AMBIENT, To, HICHER THAN 40°C. THE MAXIMUM OPERATING

CURRENT, In IS AS FOLLOWS:

85 - Ta  $I_0 = I_r$ 45

## <u>R</u>ELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS € 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES In FOR 8 SECONDS

CUSTOMER DRAWING 30VSB6 \_APPRVD\_\_\_DATE 02MAR18 JB

# TEST SPECIFICATIONS:

INDUCTANCE: 0.9 mH NOMINAL CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND:

0.0199 μF±20% 1.005 μF±20%

LINE TO LINE:

DISCHARGE RESISTOR: L/G AND L/L I.R.

330K

NO DISCHARGE RESISTOR:

6000MA (MIN.) @ 100VDC.

DATE:

DRIG:

O2MAR18

30VSB6

В

20°C AND 50% RH

## RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 1500 VAC FOR 1 MINUTE LINE TO LINE: 1450 VDC FOR 1 MINUTE

### FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.

